

To: Krysti Barksdale-Noble

From: Katie Fraser, JC Witt

Date: September 30, 2025

Subject: Follow up to 9/23 City Council Meeting Items

Dear Krysti,

Thank you and all the staff and City Council members at the City of Yorkville for your time on September 23, 2025. Below are responses to the questions that required follow-up. We look forward to further discussion and collaboration with you and your colleagues regarding these matters. Please do not hesitate to contact me with any questions or concerns.

Item 1 – Use of Glycol

PLD Response: We do not utilize propylene glycol at our data center projects in the greater Chicago area and do not intend to utilize propylene glycol at Project Steel.

Propylene Glycol is used in rare occasions in outdoor water lines when heat tracing is not sufficient to prevent pipes from freezing in extreme cold climates. In other data centers when glycol is used it stays within the closed loop system and the owner is required to adhere to strict environmental and safety standards for containing, recycling or disposing.