



- NOTES:
1. VALVE MANHOLE DIA. SHALL BE 48" FOR 10" AND 60" FOR 12" AND LARGER VALVES. VALVES UNDER 10" SHALL BE INSTALLED IN TRENCH ADAPTER VALVE BOX.
 2. VALVE VAULTS SHALL BE ADJUSTED WITH PRECAST CONCRETE RINGS TO A MAXIMUM OF 8"

UNITED CITY OF YORKVILLE

COPYRIGHT © 2014 ENGINEERING ENTERPRISES, INC.

TYPICAL VALVE MANHOLE DETAIL

| | | | | |
|---|------------------|------------------|--------------------------|--------------------|
|  Engineering Enterprises, Inc. 52 Wheeler Road Sugar Grove, Illinois 60554 Phone: (630) 466-9350 | SCALE: N.T.S. | FOLDER: YO-WA | DRAWING NUMBER: ST-03 | DRAWN BY: CLN |
| | DATE: 4/30/14 | | | REVISED: 5/7/14 |