



NOTES:

1. VALVE MANHOLE DIA. SHALL BE 48" FOR 6" AND SMALLER VALVES AND 60" FOR 8" AND LARGER VALVES.
2. MATERIAL WALL THICKNESS PRE-CAST CONC. - MIN. 1/12 "D" CAST IN PLACE CONC. MIN 6"

UNITED CITY OF YORKVILLE

COPYRIGHT © 2019 ENGINEERING ENTERPRISES, INC.

WATER MAIN PRESSURE CONNECTION DETAIL			
Engineering Enterprises, Inc. 52 Wheeler Road Sugar Grove, Illinois 60554 Phone: (630) 466-9350	SCALE: N.T.S.	FOLDER: YO-WA	DRAWING NUMBER: ST-01
	DATE: 12/03/13		DRAWN BY: CLN