



SCV



SLM



TMWP

Click image to open Product Page

Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
ALL CALCS @ GRADE	Illuminance	Fc	0.81	22.1	0.0	N.A.	N.A.
DIESEL CANOPY	Illuminance	Fc	21.68	28.3	0.0	N.A.	N.A.
GAS CANOPY	Illuminance	Fc	32.48	48.8	1.5	21.65	32.53
PAY CANOPY	Illuminance	Fc	33.71	44.6	23.2	1.45	1.92
PROPERTY LINE	Illuminance	Fc	0.00	0.1	0.0	N.A.	N.A.
INSIDE CURB	Illuminance	Fc	2.31	22.1	0.0	N.A.	N.A.

Symbol	Qty	Label	Arrangement	Description	LLD	UDF	LLF	Arr. Lum. Lumens	Arr. Watts
▲	37	A	SINGLE	SCV-LED-13L-SC-50 MTD @ 10'PAY,15'GAS,18'DIESEL	1.000	1.000	1.000	12933	84.3
■	4	B	SINGLE	SLM-LED-09L-SIL-SW-50-70CRI-SINGLE-17'POLE+3'BASE	1.000	1.000	1.000	9262	68.2
■	8	C	SINGLE	SLM-LED-09L-SIL-FT-50-70CRI-IL-SINGLE-17'POLE+3'BASE	1.000	1.000	1.000	6351	68.2
▲	8	D	SINGLE	TMWP-LED-04L-50 MTD @ 10'	1.000	1.000	1.000	4044	31.23

Based on the information provided, all dimensions and luminaire locations shown represent recommended positions. The engineer and/or architect must determine the applicability of the layout to existing or future field conditions.

This lighting plan represents illumination levels calculated from laboratory data taken under controlled conditions in accordance with the Illuminating Engineering Society (IES) approved methods. Actual performance of any manufacturer's luminaires may vary due to changes in electrical voltage, tolerance in lamps/LED's and other variable field conditions. Calculations do not include obstructions such as buildings, curbs, landscaping, or any other architectural elements unless noted. Fixture nomenclature noted does not include mounting hardware or poles. This drawing is for photometric evaluation purposes only and should not be used as a construction document or as a final document for ordering product.

Total Project Watts
Total Watts = 4187.34

LIGHTING PROPOSAL LD-148118

GAS 'N' WASH
NE CORNER IL RT47 & WATER PKWY
YORKVILLE, IL

Blank DATE6/21/19 REV SHEET 1 OF 1

SCALE: 1"=30'